

## **AL-FAROOQ CORPORATION**

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

## PRODUCT APPROVAL EVALUATION RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 42638

Date: 10/12/2023

**Detailed Product Description:** 

Manufacturer: Vitralux Windows SAS

Manufacturer Address: Km 5.6 Via Palmira Tienda Nueva, Palmira, Colombia, 760046

Model Name: SERIES 100SH ALUMINUM SINGLE HUNG WINDOW

Maximum Load: +80 PSF, -95 PSF (Small Missile Impact)

**Installation Drawings # 23-50F** 

This product complies with the High Velocity Hurricane Zone (HVHZ) testing requirements.

For maximum sizes, combination of span vs loads and anchor type refer to installation drawings.

Comparative analysis used X Yes No

## Mandatory Tests (Tested in accordance with AAMA 101/I.S.2/NAFS/TAS-202)

, ,					
Test	Description	Test Location	Test Report Date	Test Report #	Test Sealed By
ASTM E283	Air Infiltration Leakage	Fenestration Testing Laboratory, Inc	6/6/2019	FTL-10651	Idalmis Ortega, P.E.
ASTM E331 OR ASTM E547 & TAS 202	Water Penetration	Fenestration Testing Laboratory, Inc	6/6/2019	FTL-10651	Idalmis Ortega, P.E.
ASTM E330 & TAS 202	Uniform Static Air Press.	Fenestration Testing Laboratory, Inc	6/6/2019 6/25/2019	FTL-10651 FTL-10603 FTL-10595	Idalmis Ortega, P.E.
ASTM F588	Forced Entry Test	Fenestration Testing Laboratory, Inc	6/6/2019	FTL-10651	Idalmis Ortega, P.E.

## Supplemental Tests (Tested in accordance with TAS-201 and TAS-203)

Test	Description	Test Location	Test Report Date	Test Report#	Test Sealed By
FBC 1626.3	Small Missile Impact & Cyclic	Fenestration Testing Laboratory, Inc	6/6/2019	FTL-10651 FTL-10603	Idalmis Ortega, P.E.
(TAS 201 & 203)		Laboratory, me	6/25/2019	FTL-10595	

Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2023 Florida Building Code.

**Evaluation Report Engineer:** 

Jalal Faroog

PE # 81223

Al-Faroog Corporation EB # 3538

Sealed: 10/12/2023